

DWEB - All Hotels, misc - PSS #60

Ticket for tracking Circuit Breakers.

10/14/2025 06:41 PM - Sieu Ngo

| | | | |
|--|--------|------------------------|------------|
| Status: | New | Start date: | 10/14/2025 |
| Priority: | Medium | Due date: | |
| Assignee: | | % Done: | 0% |
| Category: | | Estimated time: | 0.00 hour |
| Description VA's - as new circuits breakers are added or replaced, we need to put here. For larger locations like DC/PSS/WI/BI, always ask which panel. Then once purchase is made and verified to be good, document the model number - this will help us judge what to buy instead of having the same person go back and forth making multiple trips. | | | |

History

#1 - 10/14/2025 06:46 PM - Sieu Ngo

- File QO-Breakers.png added

KP3:
Ben changed out Q0120CP breaker for Kim on 10/14 .. not more trips.....
Just like DC panels, these were Square D's QO where instead of a hook, looks like "c" attachments - see picture.

DC: L1 and B1/B2 - ordered the tandem QO from amazon - significantly cheaper.

Ben CHANGED the breaker in L side 1 broiler panel 2. He only used 2 breakers in DC. He has 1 tndem left for DC panel if we need it.

Files

| | | | |
|-----------------|--------|------------|----------|
| QO-Breakers.png | 111 KB | 10/15/2025 | Sieu Ngo |
|-----------------|--------|------------|----------|